



liftinstituut
SINCE 1933



CERTIFICATE OF CONFORMANCE

Acting under ASME A17.7.1/CSA B44.7.1 issued by Liftinstituut B.V. identification number ANSI AECO #0842
(AECO = Accredited Elevator/Escalator Certification Organization) Certification system 3 according to ISO/IEC 17067: 2013

Certificate no.	: NA19-0842-1004-008-11	Revision no.:	1
Description of the product	: Energy accumulation type buffers with non-linear characteristics		
Trademark	: ACLA		
Type	: AUTAN HE, 300400Fx, ø80 mm x 80 mm		
Model no.	: 300400F1, 300400F3, 300400F4, 300400F5, 300400F6		
Name and address of the manufacturer	: ACLA-WERKE GMBH Frankfurter Str. 142-190 D-51065 Köln, Germany		
Name and address of the certificate holder	: ACLA-WERKE GMBH Frankfurter Str. 142-190 D-51065 Köln, Germany		
Certificate issued on the basis of the following requirements	: ASME A17.7-2007 / CSA B44.7-07 (I-3 Certification of Components)		
Test laboratory / location	: ACLA, Germany		
Date and number of the laboratory report	: None		
Date of verification of conformance	: March 2022		
Annexes with this certificate	: Certificate of Conformance Report no: NA19-0842-1004-008-11 rev.1		
Additional remarks	: Load range 1.0 m/s (200 fpm): 303 - 1150 kg (668 - 2535 lb) Load range 0.63 m/s (125 fpm): 200 - 2404 kg (441 - 5300 lb) For GESRs, SPs and other information see supporting report. This revision replaces certificate NA19-0842-1004-008-11 of 04-03-2019		
Conclusion	: The Component meets the requirements of the ASME A17.7-2007 / CSA B44.7-07, taking into account any additional remarks mentioned above		

Amsterdam

Date : 03-03-2022
Valid thru : 03-03-2025

ing A.J. van Ommen
International Business
Manager

Certification decision by