



liftinstituut  
SINCE 1933



# CERTIFICATE OF COMPLIANCE

issued by Liftinstituut B.V. identification number ANAB #0842 as Certification Organization.  
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA22-0842-1004-008-19 Revision no.: -

Description of the product : Energy accumulation type buffers with non-linear characteristics

Trademark : ACLA

Type : AUTAN HE, 300401Fx, ø100 mm x 80 mm

Model no. : 300401F1, 300401F3, 300401F4, 300401F5, 300401F6

Name and address of the manufacturer : ACLA-WERKE GMBH  
Frankfurter Str. 142-190  
D-51065 Köln, Germany

Name and address of the certificate holder : ACLA-WERKE GMBH  
Frankfurter Str. 142-190  
D-51065 Köln, Germany

Certificate issued on the basis of the following requirements : ASME A17.1-2016 / CSA B44-16 with Record 17-2735  
ASME A17.1-2019 / CSA B44:19

Test laboratory / location : None

Date and number of the laboratory report : None

Date of verification of compliance : March 2022

Annexes with this certificate : Certificate of Compliance Report  
no: NA22-0842-1004-008-19

Additional remarks : This certificate is based on certificate NA19-0842-1004-008-12  
Load range 1.0 m/s (200 fpm): 400 - 1550 kg (882 - 3417 lb)  
Load range 0.63 m/s (125 fpm): 237 - 4008 kg (522 - 8836 lb)

Conclusion : The Component as referred to in this certificate meets the requirements of the ASME A17.1-2016 / CSA B44-16 or ASME A17.1-2019 / CSA B44:19, taking into account any additional remarks mentioned above

Amsterdam

Date : March 10, 2022  
Valid thru : March 10, 2025

ing A.J. van Ommen  
International Business  
Manager

Certification decision by