



liftinstituut
SINCE 1933



CERTIFICATE OF COMPLIANCE

issued by Liftinstituut B.V. identification number ANAB #0842 as Certification Organization.
Certification system 3 according to ISO/IEC 17067: 2013

Certificate no. : NA22-0842-1004-008-21 Revision no.: -

Description of the product : Energy accumulation type buffers with non-linear characteristics

Trademark : ACLA

Type : AUTAN HE, 300402Fx, $\varnothing$ 125 mm x 80 mm

Model no. : 300402F1, 300402F3, 300402F4, 300402F5, 300402F6

Name and address of the manufacturer : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Name and address of the certificate holder : ACLA-WERKE GMBH
Frankfurter Str. 142-190
D-51065 Köln, Germany

Certificate issued on the basis of the following requirements : ASME A17.1-2016 / CSA B44-16 with Record 17-2735
ASME A17.1-2019 / CSA B44:19

Test laboratory / location : None

Date and number of the laboratory report : None

Date of verification of compliance : March 2022

Annexes with this certificate : Certificate of Compliance Report
no: NA22-0842-1004-008-21

Additional remarks : This certificate is based on certificate NA19-0842-1004-008-14
Load range 1.0 m/s (200 fpm): 800 - 3001 kg (1764 - 6616 lb)
Load range 0.63 m/s (125 fpm): 500 - 5303 kg (1102 - 11691 lb)

Conclusion : The Component as referred to in this certificate meets the requirements of the ASME A17.1-2016 / CSA B44-16 or ASME A17.1-2019 / CSA B44:19, taking into account any additional remarks mentioned above

Amsterdam

Date : March 10, 2022
Valid thru : March 10, 2025

ing A.J. van Ommen
International Business
Manager

Certification decision by